

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.,**

Class IA Registered Engineer. (PANEL REG.No. ABE/TI/B/94630/96, Competent person to release structural soundness Certificate for public buildings. Chartered Engineer (India) IER(REG.No.M-111304/0), PPE IV- REG.No.F-10285. Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003. Approved Valuer/Civil Engineer.Panel Valuer of Banks .

**Certificate of Structural Soundness for the School**

**Statement accompanying the Form- A.**

1. Door Number of building : St.Joseph of Cluny Public School  
Block - 25
2. Location (Street, Name, Ward Number,  
Name of place, i.e.Corporation/Municipality/  
Panchayat/Panchayat Union/Township/  
Contonment, etc.,) : R.S.No.494 & 496  
Neyveli Township - 607 803  
Kurinjipadi Taluk  
Cuddalore District
3. Year of construction : St.Joseph Block : 1975 (Renovated in 2009)  
Silver Jubilee Block : 1993  
Sacred Heart Block : 2009  
Laboratory Block : 2009  
Nanette Block : 2000  
Auditorium Block : 2002
4. Approximate cost of construction as  
per current rates : Rs.15,00,00,000-  
(Rs.Fifteen crores only)
5. Purpose for which the building is being  
used or proposed to be used : Class rooms, Auditorium ,Laboratories  
Music room, Sports room, Maths lab  
Library, computer lab and toilets
6. Purpose for which the building has now  
been used : -do-
7. Details of construction of the building  
(particulars of the foundation soil,  
specification of the various parts  
under) :
- a) Foundation : RCC footings  
b) Basement : Brick masonry with C.M.  
c) Superstructure : Brick masonry with C.M.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng**  
**CLASS - IA REGISTERED ENGINEER,**  
**(Under Tamil Nadu Public Building Lic. Act.)**  
**COLLECTERATE PANEL ENGINEER,**  
**Chartered Engineer, Approved Valuer,**  
**Registered Structural Engineer,**  
**Reg. No: RSE / Gr-II / VR / MAY-2019 /007**  
**Villupuram Region,**  
**D.No: 3/201, First Cross Street, Friends Nagar**  
**SEMMANDALAM, CUDDALORE 607 801**

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.,**

**Class IA Registered Engineer.** (PANEL REG.No.AEE/TI/B/94630/96.Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285. Reg.No.under section 34AB of Wealth Tax Act - Category I/566 of 2002 - 2003, Approved Valuer/Civil Engineer.Panel Valuer of Banks

d) Floor and roof, are to be given	:	Cement mortar floor finishing Ceramic and marble tiles flooring and RCC roof		
e) Area of the building	:		Sq.Ft.	Sq.M.
		St.Joseph block		
		Ground floor	11940.48	1109.71
		Toilets	332.70	30.92
		First floor	11940.48	1109.71
		Silver Jubilee block		
		Ground floor	14392.58	1337.60
		First floor	14392.58	1337.60
		Fees Counter Block	773.97	71.93
		Sacred Heart block		
		Ground floor	8357.61	776.73
		First floor	8357.61	776.73
		Second floor	8357.61	776.73
		Laboratory block		
		Ground floor	4047.37	376.15
		Toilet and store room	194.86	18.11
		First floor	4047.37	376.15
		Auditorium Block		
		Ground floor	8794.79	817.36
		Toilet	40.67	3.78
		First floor	5931.67	551.27
		Nanette Block		
		Ground floor	4830.06	448.89
		First floor	4830.06	448.89
		Toilet block (G.Floor)		
		Toilet block-1	520.25	48.35
		Toilet block -2	633.87	58.91
		Toilet block-3	519.39	48.27
		Toilet block (F.Floor)		
		Toilet block-1	520.25	48.35
		Toilet block -2	633.87	58.91
		Toilet block-3	519.39	48.27

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001,(TN)

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.tng**  
**CLASS - IA REGISTERED ENGINEER,**  
 (Under Tamil Nadu Public Building Lic. Act.)  
**COLLECTERATE PANEL ENGINEER,**  
 Chartered Engineer, Approved Valuer,  
 Registered Structural Engineer,  
 Reg. No: RSE / Gr-II / VR / MAY-2019 / 007  
 Villupuram Region,



**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.,**

**Class IA Registered Engineer** (PANEL REG.No.AEE/T1/B/94650/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IFI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category D/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks


Two wheeler shed-1	792.90	73.69
Two wheeler shed -2	750.62	69.76
Two wheeler shed -3	674.87	62.72
Two wheeler shed -4	1342.09	124.73
Two wheeler shed -5	1440.01	133.83
Cycle shed -1	1275.06	118.50
Cycle shed -2	1291.20	120.00

8. Period for which licence is required : From 01-03-2023 to 31-05-2026

9. Number of persons to be accommodated : 6500 Nos ( Capacity)

“ Certified that no addition or alteration has been made to the existing (St.Joseph of Cluny Public School,Block - 25,R.S.No.494 & 496 ,Neyveli Township – 607 803 Kurinjipadi Taluk, Cuddalore District.) building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.”

Date : 02-02-2023

  
Signature of the Registered Engineer  
**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.tny**  
**CLASS - IA REGISTERED ENGINEER,**  
(Under Tamil Nadu Public Building Lic. Act.)  
**COLLECTERATE PANEL ENGINEER,**  
Chartered Engineer, Approved Valuer,  
Registered Structural Engineer,  
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007  
Villupuram Region,  
D.No: 3/201, First Cross Street, Friends Nagar  
SEMMANDALAM, CUDDALORE 607 001

Date :

Signature of the owner of the building

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001.(TN)

**Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,**

**Class IA Registered Engineer.** (PANEL REG.No.AEE/TI/B/94630/96.Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003. Approved Valuer/Civil Engineer.Panel Valuer of Banks

**Form -B**

(Form of Certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act. 1965 (Tamil Nadu Act. 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (licensing) Rules . 1966).

I certify that I have inspected the building of St.Joseph of Cluny Public School,Block - 25, R.S.No.494 & 496 ,Neyveli Township – 607 803, Kurinjipadi Taluk, Cuddalore District , mentioned in the statement and furnish below its salient technical features and the same is based on the data measurements and specifications found in the site of the subject school physically.

**I.Foundation :**

- |  |   |                   |
|--|---|-------------------|
| 1. Depth below Ground level  | : | 1.83 M.           |
| 2. Nature of soil met with at foundation level                       | : | Red gravel        |
| 3. Pressure at foundation  | : | 7.00 M.Ton/Sq.M.  |
| 4. Probable safe bearing capacity of the soil met with at foundation | : | 20.00 M.Ton/Sq.M. |

**II. Super structure :**

- |   |   |   |
|---|---|---|
| 1.Maximum stress in the most critical section of masonry and concrete | : | 1600 Kg.Sq.Cm.  |
| 2. Nature of masonry and concrete and its permissible stress          | : | Brick masonry with cement mortar-3000 ksc and concrete – 5000 ksc |

The structural soundness of the building has been verified by me with reference to ISI loading standards 878 (Latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from 01-03-2023 to 31-05-2026

Date : 02-02- 2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore - 607 001

**Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V.C.Eng**  
**CLASS - IA REGISTERED ENGINEER,**  
**(Under Tamil Nadu Public Building Lic. Act.)**  
**COLLECTERATE PANEL ENGINEER,**  
**Chartered Engineer, Approved Valuer,**  
**Registered Structural Engineer,**  
**Reg. No: RSE / Gr-II / VR / MAY-2019 / 007**  
**Villupuram Region,**  
**D.No: 3/201, First Cross Street, Friends Nagar**



**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.,**

Class IA Registered Engineer, (PANEL REG.No.AEE/TLB/94630/96. Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(Reg.No.M-111304/0), PPE IV- REG.No.P-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003. Approved Valuer Civil Engineer, Panel Valuer of Banks

Form – C

Statement to accompany The Certificate of Structural Soundness

1. Location of the building, door number, street and name of the place : St. Joseph of Cluny Public School Block - 25, R.S.No.494 & 496, Neyveli Township – 607 803, Kurinjipadi Taluk, Cuddalore District
2. Age of the building : St. Joseph Block : Renovated in 2009  
Silver Jubilee Block : 30 years  
Sacred Heart Block : 14 years  
Laboratory Block : 14 years  
Nanette Block : 23 years  
Auditorium Block : 21 years
3. Number of Storeys : Sacred heart block - Three storeyed  
Others blocks - Two storeyed
4. Short description of structures steel/ Rcc framed or load bearing masonry : RCC framed structure
5. Purpose for which the building is certified for use : Class rooms, Auditorium, Laboratories  
Music room, Sports room, Maths lab  
Library, computer lab and toilets
6. The period for which the building will be structurally sound : 3 years ( from 01-03-2023 to 31-05-2026)
7. Number of persons to be accommodated : 6500 Nos ( capacity )
8. Remarks : Building is Structurally sound and Stable

Date : 02-02-2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng**  
CLASS - IA REGISTERED ENGINEER,  
(Under Tamil Nadu Public Building Lic. Act.)  
COLLECTORATE PANEL ENGINEER,  
Chartered Engineer, Approved Valuer,  
Registered Structural Engineer,  
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007  
Villupuram Region,



D.Dis.(A2)/457/2023  
Dt : 03.02.2023

Taluk Office,  
Kurinjipadi,  
Cuddalore District,  
PIN-607302.

FORM - D


Form of licence under sub section (1) of section 6 of the Madras Public Building (Licensing) act 1965 (Madras act 13 of 1965) referred to rule 6 of the Madras Public building (Licensing rules 1966)

LICENCE

LICENCE NO: 08 /2023, E-Chalan No. 20230222012949 Dated : 22.02.2023  
Rs.1,000/- at the SUB TREASURY KURINJIPADI.

Licence is hereby granted to THE PRINCIPAL, ST.JOSEPH OF CLUNY PUBLIC SCHOOL (CBSE), BLOCK-25, NEYVELI TOWNSHIP, KURINJIPADI TALUK, CUDDALORE DISTRICT for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder.

The Period of validity of the Building Licence shall be for three years commencing from 01.04.2023 to 31.03.2026 (Inclusive of both the days).




*[Signature]*  
TAHSILDAR 3.3.23  
KURINJIPADI.

STATEMENT OF ACCOMPANY THE LICENCE

Location of the Building (Door No. Street, Number and Name of Place)	Purpose for which the building is licensed to be used as a public building	No. of Persons to be accommodated
R.S.No.494 & 496 ST.JOSEPH OF CLUNY PUBLIC SCHOOL (CBSE), BLOCK-25, NEYVELI TOWNSHIP, KURINJIPADI TALUK, CUDDALORE DISTRICT	TO RUN CBSE SCHOOL	6500 STUDENTS (SIX THOUSAND AND FIVE HUNDRED ONLY)

*[Signature]*  
Principal,  
St. Joseph of Cluny  
Public School,  
Block-25, Neyveli-607803.



*[Signature]*  
TAHSILDAR, 3.3.23  
KURINJIPADI.



**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V.,**

Class IA Registered Engineer. (PANEL REG.No.AEE/TI/B.94630/96.Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0). PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003. Approved Valuer/Civil Engineer,Panel Valuer of Banks

**Form – E**

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Act Under Section 28 of the Madras Public Buildings Licensing) Act. 1965 (Madras Act 13 of 1985) referred to in rule 7 of the Madras Public Building Licensing Rules. 1966.

- |   |  |
|---|--|
| 1. Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law  | Er.K.G.Manivachakam<br>B.E.,M.I.E.,F.I.V.,<br>Registered Engineer Class I.A<br>3/201,1st Cross Street<br>Friends Nagar<br>Cuddalore – 607 001. |
| 2. Location of the building inspected<br>D.No. Street No. Name of place i.e.<br>Municipal corporation / Municipality/<br>Panchayat or Panchayat Union<br>Township/Contonment. | St.Joseph of Cluny Public School<br>Block - 25<br>R.S.No.494 & 496<br>Neyveli Town ship<br>Kurinjipadi Taluk<br>Cuddalore District             |
| 3. Date of Inspection   | 01-02-2023   |
| 4. Purpose for which the building is used   | Class rooms, Auditorium ,Laboratories<br>Music room, Sports room, Maths lab<br>Library, computer lab and toilets                               |
| 5. Nature of defects noticed  | Nil  |
| 6. Suggestion of rectifying defects   | Nil  |
| 7. If in a dangerous condition immediate action recommended to be taken   | Nil  |

Date : 02 -02- 2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore

**Principal,  
St. Joseph of Cluny  
Public School,  
Block-25, Neyveli-607803.**

**Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng**  
**CLASS - IA REGISTERED ENGINEER,**  
**(Under Tamil Nadu Public Building Lic. Act.)**  
**COLLECTORATE PANEL ENGINEER,**  
**Chartered Engineer, Approved Valuer,**  
**Registered Structural Engineer,**  
**Reg. No: RSE / Gr-II / VR / MAY-2019 /007**  
**Villupuram Region,**  
**D.No: 3/201, First Cross Street, Friends Nagar**  
**SEMMANDALAM, CUDDALORE 607 001**