

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Dated : 02-02-2023

BUILDING SAFETY CERTIFICATE

Certified that the existing building of St.Joseph of Cluny Public School , Block - 25 in R.S.No.494 & 496 , Neyveli Township – 607 803, Kurinjipadi Taluk , Cuddalore District. Comprised of St.Joseph block : Two storeyed, Silver Jubilee block : Two storeyed, Fees Counter Block – Single storeyed, Sacred Heart block : Three storeyed, Laboratory block : Two storeyed Auditorium Block : Two storeyed, Nanette Block : Two storeyed and Occupied by St.Joseph of Cluny Public School

St.Joseph of Cluny Public School have complied with the building safety requirements In accordance with National Building Code rules and verified by the concerned officer on 02-02-2023 in the presence of The Correspondent, St.Joseph of Cluny Public School, Block-25 Neyveli Township – 607 803, and that the building is fit for occupancy up to classes XII with effect from 01-03-2023 to 31-03-2026 for a Period of three years in accordance with rules

Issued on 02-02-2023 at Cuddalore by

Signature with Seal :

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. CEng
 Authority : **CLASS - IA REGISTERED ENGINEER,**
 (Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
 Designation: **Chartered Engineer, Approved Valuer,**
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
Villupuram Region,
No: 3/201, First Cross Street, Friends Nagar
SEMMANDALAM, CUDDALORE 607 001

Address : 3/201, Ist Cross street, Friends Nagar, Cuddalore -607 001.(TN)

A. Mary Grace
Correspondent,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803.

A. Thomas
Principal,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks .

Certificate of Structural Soundness for the School

Statement accompanying the Form- A.

1. Door Number of building : St.Joseph of Cluny Public School Block - 25
2. Location (Street, Name, Ward Number, Name of place, i.e.Corporation/Municipality/ Panchayat/Panchayat Union/Township/ Contonment, etc.,) : R.S.No.494 & 496
Neyveli Township - 607 803
Kurinjipadi Taluk
Cuddalore District
3. Year of construction : St.Joseph Block : 1975 (Renovated in 2009)
Silver Jubilee Block : 1993
Sacred Heart Block : 2009
Laboratory Block : 2009
Nanette Block : 2000
Auditorium Block : 2002
4. Approximate cost of construction as per current rates : Rs.15,00,00,000-
(Rs.Fifteen crores only)
5. Purpose for which the building is being used or proposed to be used : Class rooms, Auditorium ,Laboratories
Music room, Sports room, Maths lab
Library, computer lab and toilets
6. Purpose for which the building has now been used : -do-
7. Details of construction of the building (particulars of the foundation soil, specification of the various parts under) :
 - a) Foundation : RCC footings
 - b) Basement : Brick masonry with C.M.
 - c) Superstructure : Brick masonry with C.M.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng
CLASS-IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMANDALAM, CUDDALORE 607 001

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

d) Floor and roof, are to be given	:	Cement mortar floor finishing Ceramic and marble tiles flooring and RCC roof		
e) Area of the building	:		Sq.Ft.	Sq.M.
		St.Joseph block		
		Ground floor	11940.48	1109.71
		Toilets	332.70	30.92
		First floor	11940.48	1109.71
		Silver Jubilee block		
		Ground floor	14392.58	1337.60
		First floor	14392.58	1337.60
		Fees Counter Block	773.97	71.93
		Sacred Heart block		
		Ground floor	8357.61	776.73
		First floor	8357.61	776.73
		Second floor	8357.61	776.73
		Laboratory block		
		Ground floor	4047.37	376.15
		Toilet and store room	194.86	18.11
		First floor	4047.37	376.15
		Auditorium Block		
		Ground floor	8794.79	817.36
		Toilet	40.67	3.78
		First floor	5931.67	551.27
		Nanette Block		
		Ground floor	4830.06	448.89
		First floor	4830.06	448.89
		Toilet block (G.Floor)		
		Toilet block-1	520.25	48.35
		Toilet block -2	633.87	58.91
		Toilet block-3	519.39	48.27
		Toilet block (F.Floor)		
		Toilet block-1	520.25	48.35
		Toilet block -2	633.87	58.91
		Toilet block-3	519.39	48.27

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001 (TN)

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng
CLASS - IA REGISTERED ENGINEER,
 (Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
 Chartered Engineer, Approved Valuer,
 Registered Structural Engineer,
 Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
 Villupuram Region,
 Q.No: 3/201, First Cross Street, Friends Nagar

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Two wheeler shed-1	792.90	73.69
Two wheeler shed -2	750.62	69.76
Two wheeler shed -3	674.87	62.72
Two wheeler shed -4	1342.09	124.73
Two wheeler shed -5	1440.01	133.83
Cycle shed -1	1275.06	118.50
Cycle shed -2	1291.20	120.00

8. Period for which licence is required : From 01-03-2023 to 31-05-2026

9. Number of persons to be accommodated : 6500 Nos (Capacity)

“ Certified that no addition or alteration has been made to the existing (St.Joseph of Cluny Public School,Block - 25,R.S.No.494 & 496 ,Neyveli Township – 607 803 Kurinjipadi Taluk, Cuddalore District.) building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.”

Date : 02-02-2023

Signature of the Registered Engineer

Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V. C.Eng
CLASS - IA REGISTERED ENGINEER,
 (Under Tamil Nadu Public Building Lic. Act.)
COLLECTERATE PANEL ENGINEER,
 Chartered Engineer, Approved Valuer,
 Registered Structural Engineer,
 Reg. No: RSE / Gr-II / VR / MAY-2019 /007
 Villupuram Region,
 A.No: 3/201, First Cross Street, Friends Nagar,
 SEMMANDALAM, CUDDALORE 607 001

Date :

Signature of the owner of the building

Dr. Agne
Correspondent,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001.(TN)

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/TI/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Form –B

(Form of Certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act. 1965 (Tamil Nadu Act. 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (licensing) Rules . 1966).

I certify that I have inspected the building of St.Joseph of Cluny Public School,Block - 25, R.S.No.494 & 496 ,Neyveli Township – 607 803, Kurinjipadi Taluk, Cuddalore District , mentioned in the statement and furnish below its salient technical features and the same is based on the data measurements and specifications found in the site of the subject school physically.

I. Foundation :

1. Depth below Ground level : 1.83 M.
2. Nature of soil met with at foundation level : Red gravel
3. Pressure at foundation : 7.00 M.Ton/Sq.M.
4. Probable safe bearing capacity of the soil met with at foundation : 20.00 M.Ton/Sq.M.

II. Super structure :

- 1.Maximum stress in the most critical section of masonry and concrete : 1600 Kg.Sq.Cm.
2. Nature of masonry and concrete and its permissible stress : Brick masonry with cement mortor-3000 ksc and concrete – 5000 ksc

The structural soundness of the building has been verified by me with reference to ISI loading standards 878 (Latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from 01-03-2023 to 31-05-2026

Date : 02-02- 2023

Address : 3/201, Ist Cross street, Friends Nagar, Cuddalore

Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V. C.Eng
CLASS - IA REGISTERED ENGINEER,
 (Under Tamil Nadu Public Building Lic. Act.)
COLLECTERATE PANEL ENGINEER,
 Chartered Engineer, Approved Valuer,
 Registered Structural Engineer,
 Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
 Villupuram Region,
 No: 3/201, First Cross Street, Friends Nagar
 SEMMANDALAM, CUDDALORE 607 001

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Form – C**Statement to accompany The Certificate of Structural Soundness**

- | | |
|--|--|
| 1. Location of the building, door number, street and name of the place | St. Joseph of Cluny Public School
Block - 25,
R.S.No.494 & 496 ,
Neyveli Township – 607 803,
Kurinjipadi Taluk,
Cuddalore District |
| 2. Age of the building | : St. Joseph Block : Renovated in 2009
Silver Jubilee Block : 30 years
Sacred Heart Block : 14 years
Laboratory Block : 14 years
Nanette Block : 23 years
Auditorium Block : 21 yrs |
| 3. Number of Storeys | : Sacred heart block - Three storeyed
Others blocks - Two storeyed |
| 4. Short description of structures steel/ Rcc framed or load bearing masonry | : RCC framed structure |
| 5. Purpose for which the building is certified for use | : Class rooms, Auditorium ,Laboratories
: Music room, Sports room, Maths lab
Library, computer lab and toilets |
| 6. The period for which the building will be structurally sound | : 3 years (from 01-03-2023 to 31-05-2026) |
| 7. Number of persons to be accommodated | : 6500 Nos (capacity) |
| 8. Remarks | : Building is Structurally sound and Stable |

Date : 02-02-2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. Ctny
(CLASS) IA REGISTERED ENGINEER,
 (Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
 Chartered Engineer, Approved Valuer,
 Registered Structural Engineer,
 Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
 Villupuram Region,
 D.No: 3/201, First Cross Street, Friends Nagar
 SEMMANDALAM, CUDDALORE 687 001

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Form – E

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Act Under Section 28 of the Madras Public Buildings Licensing) Act. 1965 (Madras Act 13 of 1985) referred to in rule 7 of the Madras Public Building Licensing Rules. 1966.

- | | | |
|---|---|--|
| 1.Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law | : | Er.K.G.Manivachakam
B.E.,M.I.E.,F.I.V.,
Registered Engineer Class I.A
3/201,1st Cross Street
Friends Nagar
Cuddalore – 607 001. |
| 2. Location of the building inspected
D.No. Street No. Name of place i.e.
Municipal corporation / Municipality/
Panchayat or Panchayat Union
Township/Contonment. | : | St.Joseph of Cluny Public School
Block - 25
R.S.No.494 & 496
Neyveli Town ship
Kurinjipadi Taluk
Cuddalore District |
| 3. Date of Inspection | : | 01-02-2023 |
| 4. Purpose for which the building is used | : | Class rooms, Auditorium ,Laboratories
Music room, Sports room, Maths lab
Library, computer lab and toilets |
| 5. Nature of defects noticed | : | Nil |
| 6. Suggestion of rectifying defects | : | Nil |
| 7. If in a dangerous condition immediate action recommended to be taken | : | Nil |

Date : 02 -02- 2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore-607 001

A. Mary Grace
**Correspondent,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803**

S. Mani
**Principal,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803.**

K.G. Manivachakam
Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V.C.Eng
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMMANDALAM, CUDDALORE 607 001

D.Dis.(A2)/457/2023
Dt : 03.02.2023

Taluk Office,
Kurinjpadi,
Cuddalore District,
PIN-607302.

FORM - D


Form of licence under sub section (1) of section 6 of the Madras Public Building (Licensing) act 1965 (Madras act 13 of 1965) referred to rule 6 of the Madras Public building (Licensing rules 1966)

LICENCE

LICENCE NO: 08 /2023, E-Chalan No. 20230222012949 Dated : 22.02.2023
Rs.1,000/- at the SUB TREASURY KURINJIPADI.

Licence is hereby granted to THE PRINCIPAL, ST.JOSEPH OF CLUNY PUBLIC SCHOOL (CBSE), BLOCK-25, NEYVELI TOWNSHIP, KURINJIPADI TALUK, CUDDALORE DISTRICT for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder.

The Period of validity of the Building Licence shall be for three years commencing from 01.04.2023 to 31.03.2026 (Inclusive of both the days).



[Signature]
TAHSILDAR
KURINJIPADI.

STATEMENT OF ACCOMPANY THE LICENCE

Location of the Building (Door No. Street, Number and Name of Place)	Purpose for which the building is licensed to be used as a public building	No. of Persons to be accommodated
R.S.No.494 & 496 ST.JOSEPH OF CLUNY PUBLIC SCHOOL (CBSE), BLOCK-25, NEYVELI TOWNSHIP, KURINJIPADI TALUK, CUDDALORE DISTRICT	TO RUN CBSE SCHOOL	6500 STUDENTS (SIX THOUSAND AND FIVE HUNDRED ONLY)



[Signature]
Correspondent,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803

[Signature]
Principal,
St. Joseph of Cluny
Public School,
Block-25, Neyveli-607803

[Signature]
TAHSILDAR,
KURINJIPADI.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks .

Certificate of Structural Soundness for the School

Statement accompanying the Form- A.

1. Door Number of building : St.Joseph of Cluny Public School Block - 25
2. Location (Street, Name, Ward Number, Name of place, i.e.Corporation/Municipality/ Panchayat/Panchayat Union/Township/ Contonment, etc.,) : R.S.No.494 & 496
Neyveli Township - 607 803
Kurinjipadi Taluk
Cuddalore District
3. Year of construction : St.Joseph Block : 1975 (Renovated in 2009)
Silver Jubilee Block : 1993
Sacred Heart Block : 2009
Laboratory Block : 2009
Nanette Block : 2000
Auditorium Block : 2002
4. Approximate cost of construction as per current rates : Rs.15,00,00,000-
(Rs.Fifteen crores only)
5. Purpose for which the building is being used or proposed to be used : Class rooms, Auditorium ,Laboratories
Music room, Sports room, Maths lab
Library, computer lab and toilets
6. Purpose for which the building has now been used : -do-
7. Details of construction of the building (particulars of the foundation soil, specification of the various parts under) :
 - a) Foundation : RCC footings
 - b) Basement : Brick masonry with C.M.
 - c) Superstructure : Brick masonry with C.M.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng
CLASS-IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMANDALAM, CUDDALORE 607 001